

**ILOILO II ELECTRIC COOPERATIVE, INC. (ILECO II)**

Brgy. Cau-ayan, Pototan, Iloilo
Tel Nos. (033)529-8063, (033)529-8981
Email add: ileco2bac@yahoo.com

SUPPLEMENTAL BID BULLETIN

Addendum No. 1

PUBLIC BIDDING

Supply and Delivery of Distribution Transformer and Wood Pole


This Addendum No. 1 is issued to clarify and/or amend certain provisions in the Bidding Documents issued for this project.

ADDENDUM No.	REFERENCE	AMENDMENT/INCLUSION
1	b. Statement identifying the bidder's single largest completed contract similar to the contract to be bid within the relevant period as provided in the bidding documents under Section III. Instruction to Bidders (B) Technical Documents: Folder 2 (ENVELOPE 1) Certificate of completion or official receipt(s) issued for the contract.	b. Statement identifying the bidder's single largest completed contract similar to the contract to be bid within the relevant period as provided in the bidding documents under Section III. Instruction to Bidders (B) Technical Documents: Folder 2 (ENVELOPE 1) Certificate of completion and acceptance issued for the contract.
2	Section VI. Special Conditions of Contract 7.1 For Lot 1 (Distribution Transformer), Payment shall be amortized monthly based on delivery. Payment is inclusive of VAT and all other taxes.	Section VI. Special Conditions of Contract 7.1 For Lot 1 (Distribution Transformer), payment shall be amortized for eight (8) months. For Lot 2 (Wood Poles), payment shall be amortized for (5) months. Payment is inclusive of VAT and all other taxes.
3	Section VIII. Technical Specifications Lot 1 – Procurement, Supply and Delivery of Distribution Transformer Nameplate: The transformer shall be provided with a nameplate in accordance with the latest revision of IEEE Std C57.12.00. The nameplate shall be made of stainless steel with the technical information etched on the surface and coated with black enamel.	Section VIII. Technical Specifications Lot 1 – Procurement, Supply and Delivery of Distribution Transformer Nameplate: The transformer shall be provided with a nameplate in accordance with the latest revision of IEEE Std C57.12.00. The nameplate shall be made of stainless steel or aluminum with the technical information etched on the surface and coated with black enamel.
4	Inclusions under Section VIII. Technical Specifications Lot 1 – Procurement, Supply and Delivery of Distribution Transformer Factoring Testing: ILECO II's three (3) representative factory visit and witness / acceptance test: a. Supplier shall notify ILECO II two (2) months prior to the scheduled factory witness/ acceptance test. b. The Supplier shall shoulder all the expenses for the plant visit. - If the equipment fails to perform in accordance with the specification during testing and correction cannot be made in a timely manner, the factory visit and testing will be rescheduled at full expense to the Supplier. c. If the plant visit would not be permitted due to travel restrictions, the bidder instead must submit 1 unit of any rating as a sample. The sample will undergo testing and detailed evaluation of its component.	


The herein amendment forms an integral part of the bidding documents. Correspondingly, all other provisions in the bidding documents affected by this amendment are similarly amended or modified.


This SUPPLEMENTAL/BID BULLETIN ADDENDUM No. 1 is issued this 24th day of November 2021 for guidance and information of all concerned.


ROMMYER C. CARO
BAC Chairman


RODITH C. ICHON
Member


ARCHIE L. PADILLO
Member


MA. UNA P. PADILLA
Vice Chairman


REXUS O. LESONDATO
Member