



PALAWAN ELECTRIC COOPERATIVE

Third-Party Bids and Awards Committee (TPBAC)
 Km 3.35 North National Highway, Barangay Tiniguiban, Puerto Princesa City
 paleco.csp@gmail.com; www.paleco.net; (048) 433-9144 loc. 863

BID BULLETIN NO. 02

October 27, 2023

Competitive Selection Process For the 15 MW Supply of Power in the Municipality of El Nido, Palawan

Pursuant to the Department of Energy (“DOE”) Circular No. DC2018-02-003, Series of 2018, as amended by DOE Circular No. DC2021-09-0030, Series of 2021, Palawan Electric Cooperative (“PALECO”), through the Third-Party Bids and Awards Committee (“TPBAC”) hereby issues the following amendments to the Terms of Reference (TOR) for the 15 MW supply of power in El Nido, Palawan considering the queries and suggestions submitted by the Bidders.

TERMS OF REFERENCE (TOR) AMENDMENTS

No.	Provision	Original	Amendment
1	1.6 Commercial Operation Date (COD)	Technology Target COD from issuance of Provisional Authority from ERC Conventional <u>1 year</u> + 6 months allowable extension RE-Solar <u>0-1 year</u> + 6 months allowable extension	Technology Target COD from issuance of Provisional Authority from ERC Conventional <u>2 years</u> + 6 months allowable extension RE-Solar <u>2 years</u> + 6 months allowable extension
2	2.4 Committed Energy	2.4 Committed Energy	2.4 Energy Forecast
3	2.5 Delivery Period	a. Fifteen (15) years from <u>ERC approval for both baseload and peaking load supplies</u> , non-extendable and non-renewable.	a. Fifteen (15) years from <u>COD</u> , non-extendable and non-renewable.
4	3.4 Generating Units	d. If using heat engines, each Genset shall have a rated prime capacity ranging from 3MW to 5MW operating at 720rpm for baseload; and 1MW to 2MW operating at 1800rpm for peaking load;	d. If using heat engines, each Genset shall have a rated prime capacity ranging from 3MW to 5MW for baseload and 1MW to 2MW for peaking load; for baseload supply, the Bidder must utilize medium-speed gensets rated ≤ 720 rpm. For peaking load, the Bidder may provide medium-speed gensets rated ≤ 720 rpm, or high-speed gensets rated $\leq 1,800$ rpm.
5	8.1 Replacement Power	b. SUPPLIER <u>to provide</u> Replacement Power up to the Contracted Capacity during the Delivery Period.	b. SUPPLIER <u>may assist the OFFTAKER/PALECO in sourcing for the</u> Replacement Power up to the Contracted Capacity during the Delivery Period in the <u>event of allowed and scheduled outages</u> .
6	8.3 Failure to Deliver Replacement Power	b. The SUPPLIER shall source available Replacement Power during allowed outages.	Remove provision.

All other portions of the Bidding Documents affected by the above amendments shall be made to conform to the same.

Kindly acknowledge receipt of this Bid Bulletin in the space below and return the signed copy to the TPBAC through paleco.csp@gmail.com. For inquiries, please contact TPBAC Secretariat Peter Vincent S. Mendoza at Telephone No. (048) 433-9144 loc. 863.

For your information and guidance.

Approved by: TPBAC

ATTY. WILFREDO L. TAGLE
Chairperson

RGB/ALR/MCP/JPS

We hereby acknowledge receipt and acceptance of the terms and conditions outlined in this Bid Bulletin.

Received by: _____

Name of Company: _____

Date: _____